

THE STATE  OF KANSAS

KANSAS DEPARTMENT OF AGRICULTURE
Adrian J. Polansky, Secretary of Agriculture

DIVISION OF WATER RESOURCES
David L. Pope, Chief Engineer

APPROVAL OF APPLICATION
FOR
CHANGE IN POINT OF DIVERSION
APPROPRIATION OF WATER
FILE NO. 45,574

The Chief Engineer, Division of Water Resources, Kansas Department of Agriculture, after due consideration of the written application of Gerald T. Blain, on behalf of the City of Wichita, Water and Sewer Department, 455 North Main, Wichita, Kansas, 67202, received in this office on January 30, 2006, for approval of a change in the location of the point of diversion under Approval of Application, File No. 45,574, for permit to appropriate water for beneficial use, finds that the change is reasonable and will not impair existing rights, that the change relates to the same local source of supply and that the application should be and is hereby approved.

The effective date of the change shall be the date this order is executed by the Chief Engineer, after which the authorized location of the point of diversion shall be:

one(1) pumpsite located in the Southwest Quarter of the Southwest Quarter of the Southeast Quarter (SW¹/₄ SW¹/₄ SE¹/₄) of Section 8, more particularly described as being near a point 230 feet North and 2,090 feet West of the Southeast corner of said section, in Township 23 South, Range 2 West, Harvey County, Kansas,

located substantially as shown on the topographic map accompanying the application to change the point of diversion.

This order hereby removes the requirements as set forth in Paragraph Nos. 12, 18, 19, 21, 22, 24 and 25 of the Approval of Application and Permit to Proceed of File No. 45,574, dated August 8, 2005, and modifies the requirement as set forth in Paragraph No. 23 of the Approval of Application and Permit to Proceed dated August 8, 2005 as follows:

That the pumpsite authorized herein shall be operated only when the flows in the Little Arkansas River at the Gage exceed baseflow, and will not cause the streamflow at the Gage to fall below baseflow; that baseflow is 57 cubic feet per second (c.f.s.) during the months of April 1 through September 30, and 20 c.f.s. during the months from October 1 through March 31.

Installation of the works for diversion of water shall be completed on or before December 31, 2010, or within any authorized extension of time. The applicant shall notify the Chief Engineer of the Division of Water Resources, Kansas Department of Agriculture, when construction of the works for diversion has been completed.

All diversion works into which any type of chemical or other foreign substance will be injected into the water pumped from the diversion works shall be equipped with an in-line, automatic, quick-closing check valve capable of preventing pollution of the source of the water supply. The type of valve installed shall meet specifications adopted by the Chief Engineer and shall be

RECEIVED

AUG 07 2006

STAFFORD FIELD SERVICE
DIVISION OF WATER RESOURCES

